

# Catering Vehicle/Trailer Check



Registered business		Job address		Landlord/agent				
Gas safe id: 501672 Vito°Energy 93 Mytchett Road Camberley Surrey GU16 6ES +44 1252 596300		37 Bramble Bank Frimley green GU16 6PN		Mr Mike Jones 37 Bramble Bank Frimley green GU16 6PN				
Vehicle details								
Type	VW campervan		Reg/chassis no	RA15 DJZ				
Is the cylinder housing adequate	Yes	Is LPG safety information displayed	Yes	Is a fire blanket available	Yes			
Is a fire extinguisher available	No	Is there a safety ticket displayed	Yes					
Appliance details								
No	Appliance type	Make	Model	Serial no	Appliance secured	Isolation valve fitted	Flue type	
1	Cooker/hob	Not listed	2 burner		Yes	Yes	FL	
2								
3								
4								
5								
Inspection details								
No	Operating pressure in mbar or heat input in kW	Safety devices(s) correct operation	Ventilation provision satisfactory	Visual condition of flue and termination satisfactory	Flue performance test	Appliance serviced	Spillage check	Appliance safe to use
1	30 mbar	Yes	Yes	N/A	N/A	No	N/A	Yes
2								
3								

Mobile Catering Vehicle/Trailer Check (43)

Registered business :Vito°Energy

Registered business address :93 Mytchett Road Camberley Surrey GU16 6ES

Inspection details							
4							
5							
Emergency control valve accessible			Connection hose to installation adequate		Gas tightness test satisfactory		
Regulator working pressure		30 mbar	Visual inspection satisfactory		Regulator lock up pressure		32 mbar
Details of work carried out							
Details of remedial work required							
Engineer information			Received by information			Certificate information	
Engineer name	Dave Bulbeck		Name	Mr Jones		Date	Wed 17 May 2023
Gas safe card id			Received by	Customer		Number	43
Signature	.		Signature	.		Next service due	Thu 16 May 2024