

LPG Gas Safety Certificate





Registered business	Job address	Landlord/agent			
Gas Safe number 501672 Vito*Energy 93 Mytchett Road Camberley Surrey GU16 6ES +44 1252 596300	37 Bramble Bank Frimley green GU16 6PN	N/A			
	App 1	App 2	App 3	App 4	
Inspected	Yes				
Appliance type	Cooker/hob				
Location	Bedroom				
Make/model	Unknown/California				
Flue type	FL				
Operating pressure	30mb				
Combustion analyser reading	1ppm in air with both burners				
Safety Devices correct operation	Yes				
Ventilation provision satisfactory	Yes				
Visual condition of the flue & termination satisfactory	N/A				
Flue performance checks	N/A				
Serviced	N/A				
Appliance supply pressure	30				
Appliance gas tightness test	Yes				
Electrical isolation satisfactory	N/A				
Safe to use	Yes				
Approved CO alarm fitted?	N/A				
Is CO alarm in date?	N/A				
Testing of CO alarm satisfactory	N/A				
Others					
Cylinder/final connection hoses to LAV/boat satisfactory	Yes				
Gas installation pipework visual inspection satisfactory	Yes				
Gas tightness satisfactory	Yes				
ECV accessible and operable	Yes				
LPG regulator operation pressure	30.00	mbar			
LPG regulator lock-up pressure	31.00	mbar			
Next inspection due on or before	17/06/2022				
Safety device					
Has a Warning/Advice Notice been raised?	No				
Have warning labels been attached?	No				
Has the responsible person been advised?	No				
Details of work carried out					
Carried out safety inspection on hob and bottle in motorhome					
Details of remedial work required					
Declaration of Gas Safety					
The bottle and location meets current guidelines. The 2 burner hob is in good working order and meets current guidelines					

PG Gas Safety Certificate (3)
 registered business :Vito*Energy
 registered business address :93 Mytchett Road, Camberley, Surrey, GU16 6ES

LPG Gas Safety Certificate



Engineer information	Received by information	Certificate information
Engineer name: Dave Bulbeck Gas safe card ID: Signature: 	Name: Mr Mike Jones Received by: Customer Signature: 	Date: 17/06/2021 Number : 3 Next service due: 17/06/2022

LPG Gas Safety Certificate (3)
Registered business :Vito*Energy
Registered business address :93 Mytchett Road, Camberley, Surrey, GU16 6ES